

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

May 23, 2007

RECKITT BENCKISER INC JENNIFER L DECARLO 399 INTERPACE PKWY PARSIPPANY NJ 07054-0225

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE

Manufacturer: RECKITT BENCKISER INC

Product Name: RID-X SEPTIC SYSTEM TREATMENT

Model Number(s): NA

Product File No: 20070182

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this
 product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic
 systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in
 accordance with the manufacturers instructions.

This approval supersedes the approval issued on INSERT DATE under product file number 20060522.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 07018201.DOC

RECKITT BENCKISER INC Page 2 May 23, 2007

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 Phone
(608) 267-9566 Fax
glen.schlueter@wi.gov Email

GWS:gws